



NOTES:

1. ALL 2" PIPE AND FITTINGS SHALL BE SCHEDULE 40 GALVANIZED STEEL OR BRASS WITH THREADED (NPT) JOINTS.

CITY OF MASCOTTE UTILITIES DEPARTMENT

BLOWOFF VALVE DETAIL

DATE:

DWG: BOVD

FIG: 403