


NOTES:

1. THE DEVELOPER MAY INSTALL THE SHEAR PAD RECESSED UP TO 4" BELOW FINISHED GRADE AND SOD THE RECESSED SECTION.
2. CLEARANCE BETWEEN BOTTOM OF BOLTS AND TOP OF SHEAR PAD SHALL BE 6" MINIMUM.



SECTION A-A

CITY OF MASCOTTE UTILITIES DEPARTMENT

FIRE HYDRANT ASSEMBLY DETAIL

DATE:

DWG: FH

FIG: 402