



NOTES:

1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 2 FOOT DEPTH BELOW FINISHED GRADE.

CITY OF MASCOTTE UTILITIES DEPARTMENT

GATE VALVE AND BOX DETAIL

DATE:

DWG: GVBOX

FIG: 400