ABBREV.	ITEM DESCRIPTION
AH	ALARM HORN
AL	ALARM LIGHT
ASB	ALTERNATOR TEST SWITCH
CCB	CONTROL CIRCUIT BREAKER
CCT	CONTROL CIRCUIT TRANSFORMER
DR	DUPLEX RECEPTACLE / G.F.I.
DRB	DUPLEX RECEPTACLE BREAKER
ECB	EMERGENCY CIRCUIT BREAKER
ETM	ELAPSE TIME METER
F	FUSE
FL	FLASHER
FR	FLOAT REGULATOR
G	GROUND
GR	GENERATOR RECEPTACLE
HOA	HAND-OFF-AUTO-SELECTOR
HSS	HORN SILENCE SWITCH
LA	LIGHTNING ARRESTER
MB	MOTOR BREAKER
MCB	MAIN CIRCUIT BREAKER
MCT	MAIN CIRCUIT TRANSFORMER
MT	MOISTURE AND TEMPERATURE FAILURE LIGHT
MS	MOTOR STARTER
N	NEUTRAL
OL	OVERLOAD HEATER
PA	POWER AVAILABLE LIGHT (3 REQUIRED, 1 EACH PHASE)
PAA	PUMP AUTOMATIC ALTERNATOR
PL	PILOT LIGHT
PM	PHASE MONITOR
R	RELAY
RE	RESISTOR
RL	RUN INDICATOR
RTS	REGULATOR TERMINAL STRIP
TS	TERMINAL STRIP
TTS	THERMAL TERMINAL STRIP
AD	AUTO DIALER

NOTE:

CITY OF MASCOTTE UTILITIES DEPARTMENT

PUMP STATION
CONTROL PANEL LEGEND

DATE:	DWG: LEGEND	FIG: 306