



NOTES:

1. DRAWING IS SHOWN FOR 230 VOLT POWER SUPPLY. THE LOCATION OF METER AND MAIN POWER DISCONNECT SHALL BE REVERSED FOR 480 VOLT SUPPLY.
2. WHEN TWO (2) SEPARATE CONDUCTOR-TYPE MOTORS ARE USED, CONDUIT SHALL BE INCREASED TO 3".
3. POWER SUPPLY SHALL BE UNDERGROUND ON THE LIFT STATION SITE AND SHALL BE 3 PHASE FROM A 3 PHASE SOURCE ONLY.
4. HOSE BIB SHALL HAVE A REDUCED PRESSURE ZONE BACK FLOW PREVENTER

CITY OF MASCOTTE UTILITIES DEPARTMENT		
PUMP STATION CONTROL PANEL INSTALLATION DETAIL		
DATE:	DWG:	FIG: REV. 302