



NOTES:

1. ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL.
2. UNIONS WILL BE REQUIRED FOR 2" DIAMETER AND SMALLER ASSEMBLIES ONLY.

CITY OF MASCOTTE UTILITIES DEPARTMENT		
DOUBLE DETECTOR CHECK VALVE ASSEMBLY		
DATE:	DWG: DDCVA	FIG: 503